

California Regional Water Quality Control Board, San Diego Region

April 10, 2012

In reply refer to:
213270:ccannova

Mr. Glenn Pruim
General Manager
Carlsbad Municipal Water District
5950 El Camino Real
Carlsbad, CA 92008

SUBJECT: REVIEW OF MONITORING REPORTS FOR THE CARLSBAD WATER RECYCLING FACILITY

Mr. Pruim:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the November 2011-February 2012 monthly, October-December 2011 quarterly, and January-December 2011 annual monitoring reports submitted by the Carlsbad Municipal Water District (District) in accordance with Monitoring and Reporting Program No. 2001-0352.

The San Diego Water Board identified the following violations of Section B (Discharge Specifications) of Order No. R9-2001-0352:

1. The daily maximum effluent limitation for manganese was established at 0.06 milligrams per liter (mg/L). This value was exceeded on the following occasions:

| Violation Date | Daily Maximum (mg/L) |
|----------------|----------------------|
| 10/05/2011 | 0.08 |
| 10/12/2011 | 0.08 |
| 10/19/2011 | 0.08 |
| 10/25/2011 | 0.08 |
| 11/02/2011 | 0.08 |
| 11/09/2011 | 0.08 |
| 11/15/2011 | 0.08 |

Please be informed that the San Diego Water Board has adopted Order No. R9-2011-0067 at its board meeting on February 8, 2012, which has modified the discharge specifications for iron and manganese specified in Order No. R9-2001-0123. Consequently, the San Diego Water Board is not planning to take any further enforcement action regarding the manganese effluent violations noted above at this time.

The next monitoring report required to be submitted is the March 2012 monthly monitoring report, which is due by May 1, 2012.

In the subject line of any response, please include the requested "In refer to" information located in the heading of this letter. Please contact Ms. Catherine Cannova at (858) 627-3977 or at ccannova@waterboards.ca.gov if you have any questions on this matter.

Respectfully,



Brian D. Kelley
Senior WRC Engineer
Cleanup and Land Discharge Branch

cc: Kevin M. Hardy, General Manager
Encina Wastewater Authority
6200 Avenida Encinas
Carlsbad, CA 92011-1095

| Tech Staff Info & Use | |
|-----------------------|--------|
| Regulatory Measure ID | 384190 |
| Violation ID | 922204 |
| | 922205 |
| | 922206 |
| | 922207 |
| | 922208 |
| | 922209 |
| | 922210 |